

Kitemark[®] Licence



No. KM 553763

BSI hereby grants to:

Gent by Honeywell Limited
140 Waterside Road
Hamilton Industrial Park
Leicester
LE5 1TN
United Kingdom

In respect of:

BS EN 54-2 & BS EN 54-4

Fire Panel & Power Supplies

the right and Licence to use the Kitemark in accordance with the Kitemark Licence Conditions of Contract governing the use of the Kitemark, as may be updated from time to time by BSI, and as approved by the Registrar under the Trade Marks Act 1994 (the "Conditions"). All defined terms in this Licence shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Licence provided at or from the above address.

For and on behalf of BSI:

David Ford, Director, Healthcare and Testing Services



First granted: **05 Nov 2009**

Date: **05 Nov 2009**

Page: 1 of 3



raising standards worldwide[™]

This licence remains the property of BSI and shall be returned immediately upon request. This licence does not expire.
To check its validity call +44 (0)8450 765600



Kitemark[®] Licence



No. KM 553763

Gent by Honeywell Limited
Hamilton Industrial Park, Leicester

BS EN 54 Part 2: 1998 +A1 & AC and BS EN 54 Part 4: 1998 + A1 & A2

Model Reference	Type
13270-01LB	Xenex 1 Zone Conventional Control and Indicating Equipment
13270-02LB	Xenex 2 Zone Conventional Control and Indicating Equipment
13270-04LB	Xenex 4 Zone Conventional Control and Indicating Equipment
13270-08LB	Xenex 8 Zone Conventional Control and Indicating Equipment

Certified for use with Gent by Honeywell conventional fire detection and alarm system devices.

The Xenex series of CIE are also suitable for use with the Xenex (13271-08LB) 8 Zone Repeater panel.

Options with requirements

Certified with the following options with requirements from BS EN54 Part 2:

Outputs to fire alarm devices (clause 7.8)

Delays to outputs (clause 7.11)

Test condition (clause 10)

First granted: **05 Nov 2009**

Date: **05 Nov 2009**

Page: 2 of 3

raising standards worldwide[™]

This licence remains the property of BSI and shall be returned immediately upon request. This licence does not expire.
To check its validity call +44 (0)8450 765600



Kitemark[®] Licence



No. KM 553763

Gent by Honeywell Limited
Hamilton Industrial Park, Leicester

The above products may be Kitemarked when branded with the following trademark:

For the purposes of traceability the Kitemark licence number must appear adjacent to the Kitemark symbol on all branded products.

Gent by Honeywell Product Model	Alternative Branded Model	Supplier
13270-01LB	75585-01NMB	SMS
13270-02LB	13270-02SP (Spanish version)	Gent by Honeywell
	75585-02RS	RS Components
	75585-02NMB	SMS
13270-04LB	13270-04SP (Spanish version)	Gent by Honeywell
	75585-04RS	RS Components
	75585-04NMB	SMS
13270-08LB	13270-08SP (Spanish version)	Gent by Honeywell
	75585-08RS	RS Components
	75585-08NMB	SMS

First granted: **05 Nov 2009**

Date: **05 Nov 2009**

Page: 3 of 3

raising standards worldwide[™]

This licence remains the property of BSI and shall be returned immediately upon request. This licence does not expire.
To check its validity call +44 (0)8450 765600

