



City of Chicago
Richard M. Daley, Mayor

Chicago Fire Department

Raymond Orozco
Commissioner

14th Floor
10 West 35th Street
Chicago, Illinois 60616-3799
(312) 745-3705

<http://www.cityofchicago.org/fire>

July 24, 2006

Isaac Papier, P.E.
Honeywell Life Safety
3825 Ohio Avenue
St. Charles, Illinois 60147-5465

RE: **Johnson Controls IFC2 3030 Fire Alarm Panel**

Dear Mr. Papier,

Based on the cross-listing information received, the Notifier NFS2 3030 fire alarm panel is cross-listed as the Johnson Controls IFC2 3030 fire alarm panel. Therefore, the Johnson Controls IFC2 3030 fire alarm panel is acceptable for use in the City of Chicago.

This fire alarm panel is acceptable for High Rise, Class I and Class II applications. All fire alarm panel installations will be subject to a field inspection to verify compliance with the city code.

Sincerely,

Demarre McGill
Deputy Fire Commissioner
Bureau of Fire Prevention

John Javorka, P.E.
Chief Fire Prevention Engineer
Bureau of Fire Prevention

Daniel Allen
Chief Electrical Inspector
Department of Buildings

